



TEST REPORT

Performed for: Fellowes
IBR JN: 15089
Date: 15 May, 2014

Location: Itasca, IL
Contact: Peter Maletich

Test Method: Filter Efficiency per IEST RP CC001.5
Fluid: Air
Instrumentation Upstream: Thermo Electron Model DR-2000 S/N 2178, next calibration 27 Oct, 2014
Instrumentation Downstream : Thermo Electron Model DR-40000 S/N D372, next calibration 27 Oct, 2014
Flow Rate: 220 SCFM
Conditions: Temperature 21.33C, Relative Humidity 48.24%, Barometric Pressure 734.1mmHg
Contaminant: Thermally Generated DEHS Oil Aerosol, 0.3µm mass mean diameter
Description of Samples: Pleated filter Element ZTF#2 03/27/14
Size: 14.5"x14"x2" Media Color: White

Date Received: 2 May, 2014

Sample Source: Fellowes

Filter	Net DP kPa	Port	Concentration
			µg/m3:
ZFT#2 03/27/14	0.05	Upstream	14350.0
		Downstream	3.5
		Efficiency	99.98



Notice: These data relate only to the samples tested. This report may be copied only in its entirety.
pg 1/1 Performed By: DW Data Location: DW-210

Reviewed By: _____
Susan H. Goldsmith, Director of Technical Services
IBR 11599 Morrissey Rd Grass Lake MI USA 49240 517-522-8453